

LONG TERM CARE SURVEY

SURVEY AREA	OBSERVATION	INTERVIEWING	RECORD REVIEW	EVALUATION FACTORS	CROSS REFERENCE
<p>L. Emergency Power F334 SNF 405.1134(b)</p> <p>F335</p> <ol style="list-style-type: none"> An emergency source of electrical power necessary to protect the health and safety of residents is available. 	<p>Is an emergency generator available?</p> <p>Test generator under full load conditions.</p> <p>Check items of emergency power:</p> <ul style="list-style-type: none"> - lighting - fire detection - alarms - extinguishing systems - life support systems <p>Transfer time from normal power to emergency power to occur within 10 seconds.</p> <p>Check for grounded extension cords at nurses stations.</p> <p>Where are emergency outlets?</p>			<p>As per regulations and covered by the Life Safety Code surveyor</p>	
<p>F336</p> <ol style="list-style-type: none"> Emergency power is adequate at least for lighting in all means of egress; equipment to maintain fire detection, alarm, and extinguishing systems; and life support systems. 					