

Access Control

Term	Definition/Description
EVALUATE FACILITY FOR SECURITY GUARD REQUIREMENTS	If security guards are required, the number of guards at any given time will depend on the size of the facility, the hours of operation, and current risk factors, etc.
SECURITY GUARD PATROL	Desirable for level I and II facilities and may be included as lease option. Level III, IV and V facilities will have security guard patrol based on facility evaluation.
INTRUSION DETECTION SYSTEM WITH CENTRAL MONITORING CAPABILITY	Desirable in Level I facilities, based on evaluation for Level II facilities, and required for Levels III, IV and V.
UPGRADE TO CURRENT LIFE SAFETY STANDARDS	Required for all facilities as part of GSA design requirements, (e.g. fire detection, fire suppression systems, etc.)

Entrances/Exits

Term	Definition/Description
X-RAY AND MAGNETOMETER AT PUBLIC ENTRANCES	May be impractical for Level I and II facilities. Level III and IV evaluations would focus on tenant agencies, public interface, and feasibility. Required for Level V.
REQUIRE X-RAY SCREENING OF ALL MAIL/PACKAGES	All packages entering building should be subject to x-ray screening and/or visual inspection.
HIGH SECURITY LOCKS	Any exterior entrance should have a high security lock as determined by GSA specifications and/or agency requirements.

B.3 Interior Security

Employee/Visitor Identification

Term	Definition/Description
AGENCY PHOTO ID FOR ALL PERSONNEL DISPLAYED AT ALL TIMES	May not be required in smaller facilities.