

Table 1A. Selection of Test Procedure Sections: Section 1 (Definitions) and Section 2 (Testing Conditions)

Key Equipment Features and Secondary Test Method	Sections From the Test Procedure													O	C	R									
	1.1 to 1.47	2.1 to 2.2	2.2.1	2.2.2	2.2.3	2.2.4 to 2.2.4.1	2.2.4.2	2.2.5	2.3 to 2.3.1	2.3.2	2.4 to 2.4.1	2.4.2	2.5				2.5.1 to 2.5.1.2	2.5.2 to 2.10	2.10.1	2.10.2	2.10.3	2.11 to 2.13			
I-1. Single-speed Compressor; Variable-Speed Variable Air Volume Indoor Fan	AC	AC	HP	HP		AC	HP	HP	AC	HP	HP	AC	HP	HP	AC	HP	HP	HP	HP	AC					
	HP	HP	HP	HP		HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP				
	HH	HH	HH	HH		HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH				
	AC	AC	HP	HP		AC	HP	HP	AC	HP	HP	AC	HP	HP	AC	HP	HP	HP	HP	AC	HP				
I-2. Single-speed Compressor Except as Covered by "I-1"	AC	AC	HP	HP		AC	HP	HP	AC	HP	HP	AC	HP	HP	AC	HP	HP	HP	HP	AC	HP				
	HP	HP	HP	HP		HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP			
	HH	HH	HH	HH		HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH			
I-3. Two-capacity Compressor	AC	AC	HP	HP		AC	HP	HP	AC	HP	HP	AC	HP	HP	AC	HP	HP	HP	HP	AC	HP				
	HP	HP	HP	HP		HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP			
	HH	HH	HH	HH		HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH			
I-4. Variable-speed Compressor	AC	AC	HP	HP		AC	HP	HP	AC	HP	HP	AC	HP	HP	AC	HP	HP	HP	HP	AC	HP				
	HP	HP	HP	HP		HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP	HP			
	HH	HH	HH	HH		HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH	HH			
II-1. Ducted																									
II-2. Non-Ducted																									
III. Special Features																									
IV. Secondary Test Method																									

Legend for Table Entries:

Categories I and II: AC = applies for an Air Conditioner that meets the corresponding Column 1 "Key Equipment ..." criterion

HP = applies for a Heat Pump that meets the corresponding Column 1 "Key Equipment ..." criterion

HH = applies for a Heating-only Heat pump that meets the corresponding Column 1 "Key Equipment ..." criterion

G = ganged mini-splits or multi-splits;

H = heat pump with a heat comfort controller;

M = units with a multi-speed outdoor fan.

Category IV: O = Outdoor Air Enthalpy Method; C = Compressor Calibration Method; R = Refrigerant Enthalpy Method