

Table 1B. Selection of Test Procedure Sections: Section 3 (Testing Procedures)

Sections From the Test Procedure	Key Equipment Features and Secondary Test Method	3. to 3.14	3.14.1 to 3.14.1.1	3.14.2	3.14.3	3.14.4 to 3.14.4.2	3.14.4.3	3.14.4.4	3.14.5	3.14.6 to 3.14.7	3.15 to 3.1.8	3.19	3.2.1	3.2.2 to 3.2.2.2	3.2.3	3.2.4	3.3 to 3.5	3.5.1	3.5.2	3.5.3	
I-1. Single-speed Compressor; Variable-speed, Variable Air Volume Indoor Fan	AC HP HH			AC HP					HP HH		AC HP HH HH	HP HP HH		AC HP			AC HP			AC HP	
											AC HP HH HH										
												AC HP HH HH									
												AC HP HH HH									
I-2. Single-speed Compressor Except as Covered by "I-1"	AC HP HH																				
I-3. Two-capacity Compressor	AC HP HH																				
I-4. Variable-speed Compressor	AC HP HH																				
II-1. Ducted																					
II-2. Non-Ducted																					
III. Special Features																					
IV. Secondary Test Method																					

Legend for Table Entries:

Categories I and II: AC

HP

HH

G

H

M

O

= applies for an Air Conditioner that meets the corresponding Column 1 "Key Equipment..." criterion

= applies for a Heat Pump that meets the corresponding Column 1 "Key Equipment..." criterion

= applies for a Heating-only Heat pump that meets the corresponding Column 1 "Key Equipment..." criterion

= ganged mini-splits or multi-splits;

= heat pump with a heat comfort controller;

= units with a multi-speed outdoor fan.

= Outdoor Air Enthalpy Method; C = Compressor Calibration Method; R = Refrigerant Enthalpy Method