

Table 1B. Selection of Test Procedure Sections: Section 3 (Testing Procedures) (continued)

Key Equipment Features and Secondary Test Method	Sections From the Test Procedure	3.6.1	3.6.2	3.6.3	3.6.4	3.6.5	3.7 to 3.8.1	3.9 to 3.10	3.11	3.11.1 to 3.11.1.3	3.11.2	3.11.3	3.12
	I-1. Single-speed Compressor; Variable-speed, Variable Air Volume Indoor Fan	HP HH	HP HH				HP HH	HP HH	AC HP HH	AC HP HH			AC HP HH
	I-2. Single-speed Compressor Except as Covered by "I-1"	HP HH					HP HH	HP HH	AC HP HH	AC HP HH			AC HP HH
	I-3. Two-capacity Compressor			HP HH			HP HH	HP HH	AC HP HH	AC HP HH			AC HP HH
	I-4. Variable-speed Compressor				HP HH		HP HH	HP HH	AC HP HH	AC HP HH			AC HP HH
	II-1. Ducted												
	II-2. Non-Ducted												
	III. Special Features					H							
	IV. Secondary Test Method									O	C	R	

Legend for Table Entries:

Categories I and II: AC = applies for an Air Conditioner that meets the corresponding Column 1 "Key Equipment . . ." criterion

HP = applies for a Heat Pump that meets the corresponding Column 1 "Key Equipment . . ." criterion

HH = applies for a Heating-only Heat pump that meets the corresponding Column 1 "Key Equipment . . ." criterion

Category III: G = ganged mini-splits or multi-splits;

H = heat pump with a heat comfort controller;

M = units with a multi-speed outdoor fan.

Category IV: O = Outdoor Air Enthalpy Method; C = Compressor Calibration Method; R = Refrigerant Enthalpy Method