

Table 1C. Selection of Test Procedure Sections: Section 4 (Calculations of Seasonal Performance Descriptors)

| Key Equipment Features and Secondary Test Method | Sections From the Test Procedure | 4 to 4.1 | 4.1.1 | 4.1.2 to 4.1.2.2 | 4.1.3 to 4.1.3.4 | 4.1.4 to 4.1.4.3 | 4.2 | 4.2.1 | 4.2.2 | 4.2.3 to 4.2.3.4 | 4.2.4 to 4.2.4.3 | 4.2.5 to 4.2.5.4 | 4.3 to 4.3.2 | 4.4 |
|---|----------------------------------|----------|----------|------------------|------------------|------------------|----------|----------|----------|------------------|------------------|------------------|--------------|----------------|
| I-1. Single-speed Compressor; Variable-speed Variable Air Volume Indoor Fan | AC HP | AC HP | AC HP | AC HP | AC HP | AC HP | HP HH | HP HH | HP HH | | | | HP | AC HP HH |
| I-2. Single-speed Compressor Except as Covered by "I-1" | | AC HP | | | | | HP HH | HP HH | | | | | HP | AC HP HH |
| I-3. Two-capacity Compressor | AC HP | | | | AC HP | | HP HH | | | HP HH | | | HP | AC HP HH |
| I-4. Variable-speed Compressor | AC HP | | | | | AC HP | HP HH | | | | HP HH | | HP | AC HP HH |
| II-1. Ducted | | | | | | | | | | | | | | |
| II-2. Non-Ducted | | | | | | | | | | | | | | |
| III. Special Features | | | | | | | H | | | | | H | | |
| IV. Secondary Test Method | | | | | | | | | | | | | | |

Legend for Table Entries:

Categories I and II: AC = applies for an Air Conditioner that meets the corresponding Column 1 "Key Equipment ..." criterion

HP = applies for a Heat Pump that meets the corresponding Column 1 "Key Equipment ..." criterion

HH = applies for a Heating-only Heat pump that meets the corresponding Column 1 "Key Equipment ..." criterion

Category III: G = ganged mini-splits or multi-splits;

H = heat pump with a heat comfort controller;

M = units with a multi-speed outdoor fan.

Category IV: O = Outdoor Air Enthalpy Method; C = Compressor Calibration Method; R = Refrigerant Enthalpy Method