

Table F219.3 Receivers for Assistive Listening Systems

| Capacity of Seating in Assembly Area | Minimum Number of Required Receivers | Minimum Number of Required Receivers Required to be Hearing-aid Compatible |
|--------------------------------------|-------------------------------------------------------|----------------------------------------------------------------------------|
| 50 or less | 2 | 2 |
| 51 to 200 | 2, plus 1 per 25 seats over 50 seats ¹ | 2 |
| 201 to 500 | 2, plus 1 per 25 seats over 50 seats ¹ | 1 per 4 receivers ¹ |
| 501 to 1000 | 20, plus 1 per 33 seats over 500 seats ¹ | 1 per 4 receivers ¹ |
| 1001 to 2000 | 35, plus 1 per 50 seats over 1000 seats ¹ | 1 per 4 receivers ¹ |
| 2001 and over | 55, plus 1 per 100 seats over 2000 seats ¹ | 1 per 4 receivers ¹ |

1. Or fraction thereof.

F220 Automatic Teller Machines and Fare Machines

F220.1 General. Where automatic teller machines or self-service fare vending, collection, or adjustment machines are provided, at least one of each type provided at each location shall comply with 707. Where bins are provided for envelopes, waste paper, or other purposes, at least one of each type shall comply with 811.

Advisory F220.1 General. If a bank provides both interior and exterior ATMs, each such installation is considered a separate location. Accessible ATMs, including those with speech and those that are within reach of people who use wheelchairs, must provide all the functions provided to customers at that location at all times. For example, it is unacceptable for the accessible ATM only to provide cash withdrawals while inaccessible ATMs also sell theater tickets.

F221 Assembly Areas

F221.1 General. *Assembly areas* shall provide *wheelchair spaces*, companion seats, and designated aisle seats complying with F221 and 802. In addition, lawn seating shall comply with F221.5.

F221.2 Wheelchair Spaces. *Wheelchair spaces* complying with F221.2 shall be provided in *assembly areas* with fixed seating.