

Based on standard U.S. Government tests

# ENERGYGUIDE

Heat Pump  
Cooling and Heating  
Split System

XYZ Corporation  
Model 12345

Compare the Energy Efficiency of this  
Heat Pump with Others Before You Buy.

This Model (Cooling)  
13.4SEER

Energy efficiency range of all similar models

Least  
Efficient  
10.9

Most  
Efficient  
18.60

SEER, the Seasonal Energy Efficiency Ratio, is a measure of energy efficiency for heat pumps when cooling.

This Model (Heating)  
8.4HSPF

Energy efficiency range of all similar models

Least  
Efficient  
7.10

Most  
Efficient  
10.55

HSPF, the Heating Seasonal Performance Factor, is a measure of energy efficiency for heat pumps when heating.

- These energy ratings are based on U.S. Government standard tests of this condenser model combined with the most common coil. The ratings will vary slightly with different coils
- Federal law requires the seller or installer of this appliance to make available a fact sheet or directory giving further information about the efficiency and operating cost of this equipment. Ask for this information.

Important: Removal of this label before consumer purchase violates the Federal Trade Commission's Appliance Labeling Rule (16 C.F.R. Part 305).